

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

PERKINS Did Not Meet Monitoring Requirements

Our water system violated drinking water requirements pertaining to the contaminant(s) of concern listed below. Although none of these violations are considered emergencies, as our customers, you have a right to know what happened and what we are doing, or have done, to correct these violations. Customers are not at risk and there is no reason to suspect any potential adverse health effects. Alternative water supplies are not needed.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the following monitoring periods, we did not monitor or test for the following contaminants, and therefore cannot be sure of the quality of your drinking water during that time:

<u>Contaminant</u>	<u>Begin Date</u>	<u>End Date</u>	<u># of Samples Required</u>	<u># of Samples Missing</u>
CHLORINE	4/1/2022	4/30/2022	3	3
TOTAL COLIFORM	4/1/2022	4/30/2022	3	3
LEAD & COPPER	7/1/2022	12/31/2022	20	11
WATER QUALITY PARAMETER	7/1/2022	12/31/2022	6	6
WATER QUALITY PARAMETER	7/1/2022	12/31/2022	2	1

What should I do? There is nothing you need to do at this time.

What happened? What is being done? We missed taking several samples. We have or will take the samples in the future.

We anticipate resolving the problem: The problem has been resolved or will be resolved as soon as the samples are taken.

For more information, please contact: Bob Ernst, City Manager at 405-547-2445 or P.O. BOX 9, PERKINS OK, 74059

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Monitoring Public Notice

OK2006012

Date Distributed:

Aug. 28, 2023