



August 02, 2023

Client: Perkins PWA

PO Box 9

Perkins, OK 74059

Requested By: -



National
Environmental
Laboratory
Accreditation
Program
ODEQ TNI Certified

Sample Project Name: Wastewater

Date Samples Received: July 25, 2023 Time: 10:08 sample temp upon arrival at lab = 14.80°C - On Ice

Matrix: Waste Water

Lab Log Numbers: **FG25024-01** **FG25024-02**

Work Order: FG25024

Report # FG25024-0802230848

EPA Lab ID#'s: **Stillwater OK00092** **Tulsa OK00983** **OKC OK00129** **ICR OK 001**

Oklahoma Certification: Stillwater NELAP WasteWater, ODEQ 8316/ Drinking Water, DEQ D9602
NELAP Tulsa WasteWater, ODEQ 9905 / Drinking Water, DEQ D9901
Oklahoma City NELAP WasteWater ODEQ 7202 / Drinking Water, DEQ D9937

Kansas Certification: Stillwater NELAP CERT # E-10219

Method Reference: 40 CFR 136, 141, and 261 Methods for Chemical Analysis of Water and Wastes EPA-600/4-79-020, March 1983. Test Methods for Evaluating Solid Wastes, SW-846, Final Update VI. Standard Methods 2005 (21st Edition), Standard Methods 2011 (22nd Edition), Standard Methods 2017 (23rd Edition) for the Examination of Water and Wastewater.

Analysis Reference: If qualifiers present in "Prep Info" or "Analysis Info", then analysis performed as follows: @= Tulsa Lab and * = OKC Lab. If no qualifiers present, then analysis performed at Stillwater Lab.

Accurate Environmental Laboratories certify that the test results performed at the Stillwater lab meet all requirements of NELAP. Any exceptions to this can be found in the report footer or Quality Control Section of the report.

This report is to only be replicated in its entirety.

Accurate Environmental sampling protocol was followed for any sampling performed by Accurate Field Services.

Sample: WWTP

Location Code:

PWSID#:

Collection Type: Grab

Sample Time: 7/25/23 8:30

Lab Log# FG25024-01

Method/Parameter	Test	Result	Notes	PQL#	Prep Info	Analysis Info
Ecoli. m-ColiBlue24 MF, Hach 10029	Escherichia Coliform	20000 CFU/100ml	TNTC-###	1.00	07/25/23 16:05 JGB	07/26/23 15:20 JGB

Sample: WWTP

Location Code:

PWSID#:

Collection Type: Grab

Sample Time: 7/25/23 8:35

Lab Log# FG25024-02

Method/Parameter	Test	Result	Notes	PQL#	Prep Info	Analysis Info
BOD5 SM5210 B	Biochemical Oxygen Demand	130 mg/L		2.00	07/26/23 07:45 RMM	07/31/23 08:15 JGB
Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	132 mg/L		50.0	07/26/23 12:58 CPL	08/01/23 15:05 CPL

Notes and Definitions

TNTC- TNTC - Too Numerous To Count. The actual value is higher than reported. The final result is our best estimate.

MCL Analyte concentration may exceed Maximum Contaminant Limit (MCL) for EPA Primary or Secondary Drinking Water Regulations.

Analyte concentration may exceed regulatory limit.

PQL Practical Quantitation Limit - the method reporting limit (MRL) adjusted for any dilutions or other changes made to the sample to deal with interferences/matrix effects

BPQL Below Practical Quantitation Limit (if applicable).

The "Prep Date" of the QC analysis coincides with the characters of the appropriate QC Lab ID. (Example: 19 A 02 15 - BLK = 2019, Jan 2, Batch #15 - Blank)

Lab Manager



Quality Control Data

Blank Data

QC Lab #	Test Group	Test	Result	PQL	Flags
23G2605-BLK1	BOD5 SM5210 B	Biochemical Oxygen Demand	BPQL mg/L	2.00	
23G2560-BLK1	Ecoli. m-ColiBlue24 MF, Hach 10029	Escherichia Coliform	BPQL CFU/100 ml	1.00	
23G2560-BLK2	Ecoli. m-ColiBlue24 MF, Hach 10029	Escherichia Coliform	BPQL CFU/100 ml	1.00	
23G2667-BLK1	Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	BPQL mg/L	2.50	

Duplicate Sample Data

QC Lab #	Test Group	Test Name	Source	Dup Result	Samp Result	% RPD	RPD Limit	Flags
23G2667-DUP2	Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	FG25024-02	138	132	4	10	

Laboratory Control Sample Data

Lab QC#	Test Group	Test Name	LCS Result	Spike Level	Units	% Rec.	Control Limits	Flags
23G2605-BS1	BOD5 SM5210 B	Biochemical Oxygen Demand	208	198.0	mg/L	105	84.6 - 115.4	
23G2667-BS1	Total Suspended Solids SM2540D 22nd ed. 2011	Total Suspended Solids	270	250.0	mg/L	108	80 - 120	

* Complete Entire COC to be in Compliance*

RUSH

Due Date _____



Chain of Custody

Client Name- **Perkins PWA**
 Project Name- **Wastewater**

Sample Preserv. & Container →	ICE 125 mL Na ₂ S ₂ O ₃	IL N/P							
Analysis Requested →	E-Coli MF	TSS/BOD							
# of Container ↓	1	1							

Accurate Work Order #	Date Sample Taken	Time Sample Taken	Matrix or Source (Refer below)	Grab (G) or Comp (C)	Client I.D. / Sample Location or DEQ / EPA Location Code	Field Results (pH, Temp, Chlorine, ...) (note analysis & units)		
FG25024	7/25/23	8:30a	WW	G	WWTP			
-01	7/25/23	8:35a	WW	G	WWTP			
-02								

On-Site Info Raw Alkalinity (TOC Raw)= _____ mg/L Turbidity (E.Coli)= _____ ntu

Matrix Codes DW = Drinking Water WW = Wastewater SL = Sludge O = Other _____

E.Coli Source- GWUDI-FS= Groundwater under direct influence of Flowing Stream GWUDI-RL= Groundwater under direct influence of Reservoir/Lake

Field Instrument Calibration -				
Meter Type	Standards	Final Read.	Date . Time	Initials

Comments

-- All samples are scheduled to be disposed of in 4 weeks of receipt at Accurate.--

Certification by Company Official: I hereby certify that the above sampling occurred during a period such that the sample(s) is/are representative of a typical operating day discharge for the above facility. **Signature:** *James Sauls* **Date/Time:** 7-25-23 8:35

Sampled By: *James Sauls* **Company:** City of Perkins **Sample Method:** Grabe

Relinquished By:	Date/Time	Received By:	Date/Time
<i>James Sauls</i>		<i>J. Schmitt</i>	
<input checked="" type="checkbox"/> Relinquished to Lab By:	Date/Time 10:08	Received at Lab By:	Rec'd °C 14.8 Date/Time 7-25-23/10:08
<input type="checkbox"/> Rel'd to Log-In Fridge By:			

Reporting Requirements (standard 10-15 working days) **Compliance Reporting?** Yes or No (DMR, PWS,) **Oklahoma PWS ID #** **OK2006012** **RUSH Request** (if available) _____ (Working Days)

Mail Report: City of Perkins Address: PO Box 9 Perkins, OK 74059 Phone #: 405-714-7859 Fax #: 405-547-5440 Email: citymanager@cityofperkins.net, jsauls@cityofperkins.net, elovelace@cityofperkins.net, cbeitz@cityofperkins.net	Mail Invoice: Accounts Payable City of Perkins Address: PO Box 9 Perkins, OK 74059 cityclerk@cityofperkins.net Phone #: 405-547-2445 Fax #: 405-547-5440 Bid # - _____ PO # - _____ 091020 tkw
--	---

www.accuratelabs.com (800) 516-5227	505 South Lowry Street Stillwater, OK 74074 Phone: (405) 372-5300 Fax: (405) 372-5396	3910 East 51 st Street Tulsa, OK 74135 Phone: (918) 663-5400 Fax: (918) 663-6300	12036 N. Pennsylvania Oklahoma City, OK 73120 Phone: (405) 751-3132 Fax: (405) 751-3108
--	--	--	--

Failure to complete this Chain of Custody form correctly may delay turnaround time of analytical reporting.